

State of California  
AIR RESOURCES BOARD

Executive Order G-70-70-AC

Modification of Certification of the  
Healy Phase II Vapor Recovery System  
for Gasoline Dispensing Facilities

WHEREAS, the Air Resources Board (the "Board") has established, pursuant to Sections 39600, 39601 and 41954 of the Health and Safety Code, certification procedures for systems designed for the control of gasoline vapor emissions during motor vehicle fueling operations ("Phase II vapor recovery systems") in its "Certification Procedures for Gasoline Vapor Recovery Systems at Service Stations" as last amended December 4, 1981 (the "Certification Procedures"), incorporated by reference in Section 94001 of Title 17, California Code of Regulations;

WHEREAS, the Board has established, pursuant to Sections 39600, 39601 and 41954 of the Health and Safety Code, test procedures for determining the compliance of Phase II vapor recovery systems with emission standards in its "Test Procedures for Determining the Efficiency of Gasoline Vapor Recovery Systems at Service Stations" as last amended September 1, 1982 (the "Test Procedures"), incorporated by reference in Section 94000 of Title 17, California Code of Regulations;

WHEREAS, James W. Healy of Healy Systems, Inc., has requested certification of modifications to the Healy Phase II vapor recovery systems, including the Healy Model 400 vapor recovery nozzle and higher vacuum level setting; and

WHEREAS, the modified Healy Phase II vapor recovery system with higher vacuum level settings and associated modifications, and the Model 400 nozzle, has been evaluated pursuant to the Board's Certification Procedures and Test Procedures; and

WHEREAS, I find that the modified Healy Phase II vapor recovery system conforms with all the requirements set forth in Sections I through VII of the Certification Procedures, and results in a vapor recovery system which is at least 95 percent effective for attendant and/or self-serve use at gasoline service stations when used in conjunction with a Phase I vapor recovery system which has been certified by the Board; and

WHEREAS, Section VIII-A of the Certification Procedures provides that the Executive Officer shall issue an order of certification if he or she determines that the vapor recovery system conforms to all of the requirements set forth in Sections I through VII of the Certification Procedures.

NOW THEREFORE, IT IS HEREBY ORDERED that the certification, Executive Order G-70-70-AB, issued October 2, 1986, is hereby modified to incorporate the Healy Model 400 vapor recovery nozzle, vacuum level adjustment and associated modifications.

Certification Executive Order G-70-70-AC

IT IS FURTHER ORDERED that the modified system is certified to be at least 95 percent effective in the self-serve and/or attendant use at gasoline service stations when used with a Board-certified Phase I vapor recovery system. A list of the equipment certified for use with the Healy vapor recovery system may be found in Exhibit 1. An ordering guide detailing the product codes of certified hoses, swivels and breakaways is in Exhibit 2. The specifications for the Healy System with Model 100 jet pumps are contained in Exhibit 3. The specifications for the Healy System with a central vacuum unit are contained in Exhibit 4. The Healy System vapor return leak tightness test procedure comprises Exhibit 5.

IT IS FURTHER ORDERED that the Healy vapor recovery nozzles certified herein must be capable of fueling, without the use of nozzle spout extenders, any motor vehicle that may be fueled at service stations not equipped with vapor recovery systems.

IT IS FURTHER ORDERED that compliance with the certification requirements and rules and regulations of the Division of Measurement Standards of the Department of Food and Agriculture, the State Fire Marshal's Office, and the Division of Occupational Safety and Health of the Department of Industrial Relations is made a condition of this certification.

IT IS FURTHER ORDERED that the systems certified hereby shall perform in actual use with the same effectiveness as the certification test systems. Compliance with this performance criterion shall be a condition of this certification, and failure to meet this criterion shall constitute grounds for revocation, suspension or modification of this certification.

IT IS FURTHER ORDERED that the certified Healy Phase II vapor recovery systems shall, at a minimum, be operated in accordance with the manufacturer's recommended maintenance intervals and shall use the manufacturer's recommended operation, installation, and maintenance procedures.

IT IS FURTHER ORDERED that the following requirements are made a condition of certification for any installation with a central vacuum unit (Model 8500 Multi-Jet or Model 9000 Mini-Jet) which was installed or modified to increase the vacuum level setting after July 1, 1992, or for any installation with a central vacuum unit for which the normal operating level is greater than 40" water column. The owner or operator of the installation shall conduct the leak test in Exhibit 5 of this Order at least once in each twelve month period. Test results which demonstrate that the installation is leak free as specified in Exhibit 5 shall be submitted to the local district. The local district may impose more stringent test frequency requirements or test procedures.

IT IS FURTHER ORDERED that any alteration of the equipment, parts, design, or operation of the systems certified hereby, is prohibited, and deemed inconsistent with this certification, unless such alteration has been approved by the Executive Officer or his/her designee.

Certification Executive Order G-70-70-AC

IT IS FURTHER ORDERED that the Healy Phase II vapor recovery nozzles, jet pumps (Model 100 Jet Pump, Model 8500 Multi-Jet and Model 9000 Mini-Jet) and control valves shall be 100 percent performance checked at the factory including checks of proper operation of all aspects of performance.

IT IS FURTHER ORDERED that the certified Healy Phase II vapor recovery system shall be performance tested during installation for ability to dispense gasoline and collect vapors without difficulty in the presence of the station manager or other responsible individual. The station manager, owner or operator shall also be provided with instructions on the proper use of the Healy Phase II vapor recovery system, its repair and maintenance, and where system replacement and system components can be readily obtained. A copy of the Healy Phase II vapor recovery system warranty shall be made available to the station manager, owner or operator.

Executed at Sacramento, California this 23<sup>rd</sup> day of June, 1992.



James D. Boyd  
Executive Officer

Attachments

**Exhibit 1**

**Executive Order G-70-70-AC**

**List of Components for Healy Phase II Vapor Recovery Systems**

		<u>Vacuum Level Items May be Used With:</u>			
		(Operating Range With Vapor Flow)			
Item/ Model	State Fire Marshal ID	15 - 30"	30 - 40"	60 - 80"	Comments
<b><u>Nozzles</u></b>					
Model 200	005:024:002	X	X		
Model 200(X)	005:024:002			X	"X" in serial number indicates higher setting
Model 400	005:027:010			X	
<b><u>Vacuum Unit</u></b>					
Model 100	005:024:004	X			Individual jet pumps - one per nozzle *
Model 8500	005:027:008		X	X	Multi-jet unit - one per station
Model 9000	005:027:009			X	Mini-jet unit - one per 8 nozzles *
* Capable of simultaneous operation					
<b><u>Pressure/Vacuum Valves</u> (Use Required Except as Indicated by *)</b>					
VAREC 2010-811-2		X *	X		Pressure release setting 1.0" water column
Hazlett H-PVB-1-RED		X *	X		Pressure release setting 1.0" water column
Hazlett H-PVB-1-BLU		X *	X		Pressure release setting 2.5" water column
CARB certified P/V valve		X *	X	X	Pressure setting to be at least 2.0" and not to exceed 3.0" wc; vacuum setting to be at least 1/2 oz. and not to exceed 8.0" wc.
<b><u>Coaxial Product/Vapor Hose</u></b>					
75B (3/4")	005:027:003	X	X	X	Maximum hose length 13 feet.
	005:027:004	X	X	X	
88B (7/8")	005:024:005	X	X	X	Note: See Exhibit 2 for approved codes.
<b><u>Hose Adapter Assemblies</u></b>					
CX Series	005:024:005	X	X	X	
CX6-MPD	005:027:002	X	X	X	

Exhibit 1, Page 2

Executive Order G-70-70-AC

List of Components for Healy Phase II Vapor Recovery Systems

Item/ Model	State Fire Marshal ID	Vacuum Level Items May be Used With: (Operating Range With Vapor Flow)			Comments
		15 - 30"	30 - 40"	60 - 80"	

Emergency Breakaway

Model 8701	005:027:001	X	X	X	
------------	-------------	---	---	---	--

Flow Control Mechanism

CX6-VV1	005:027:012	X	X	Refer to Figure 4-A
CX6-VV2	005:027:011	X	X	Refer to Figure 4-A
Part #175		X	X	Refer to Figures 4-F and 4-G

(Skinner Valve X5L37910 120 Volt 60 Cycle explosion-proof flow control valve)

## Exhibit 2

Healy System Hose, Swivel and Breakaway  
Product Codes

## ORDERING GUIDE

## HOW TO ORDER HEALY SYSTEM HOSE ASSEMBLIES

## PRODUCT CODE EXAMPLE

7	5	B	1	0	5	B	1	Y	1	M
---	---	---	---	---	---	---	---	---	---	---

## LEGEND

## DISPENSER TYPE

- (M) Multiproduct
- (S) Standard

## HOSE ADAPTER THREAD

- (1) Pipe\*
- (2) Straight\*\*

## BREAKAWAY

- (Y) Yes
- (N) No

## NOZZLE THREAD

- (1) Pipe\*
- (2) Straight\*\*

## SWIVEL TYPE

- (S) Straight
- (B) Ball\*\*\*

## OVERALL LENGTH

## HOSE COLOR

- (B) Black
- (G) Green
- (R) Red
- (Y) Yellow

## HOSE SIZE

- (75) 3/4"
- (88) 7/8"

—(090) 9.0'

—(095) 9.5'

—(100) 10.0'

—(105) 10.5'

—(110) 11.0'

—(115) 11.5'

—(120) 12.0'

—(125) 12.5'

—(130) 13.0'

\*#200 Nozzles have  
pipe thread.\*\*Future Nozzle and  
Hose Adapters will  
have straight thread  
and O-ring seal.\*\*\*Available on 3/4"  
Hose only

The above is an example of how to order a 3/4" black hose, 10 1/2' long, with universal swivel and a breakaway, when using a Healy #200 nozzle on a multiproduct dispenser application.

Executive Order G-70-70-AC

Exhibit 3

Specifications for the Healy System with Model 100 Jet Pumps

Drawings of typical installations of Healy vapor recovery systems with Model 100 jet pumps are shown in Figures 3-A, 3-B, 3-C, 3-D, 3-E, 3-F and 3-G

Nozzles

1. Model 200 nozzles are required with Model 100 systems. (Model 200(X) and Model 400 nozzles may not be used.)
2. Leaded and unleaded spouts are interchangeable.
3. The nozzle must shut off at a vacuum of -10 inches water column or less and at a pressure of +10 inches water column or greater.
4. Flow rate is limited to 10 gallons or less per minute.
5. The normal operating range in the nozzle boot is -1/4 inch water column to zero (atmospheric pressure). Readings taken during a fueling of at least ten gallons, excluding the first gallon and the last gallon dispensed, should be relatively stable. Fluctuations (except during the first or last gallon) indicate a defective nozzle. A vacuum of -1/2 inch or more, or a pressure of 1/4 inch or more, indicate a defective nozzle or system. (Note: vacuum or pressure levels outside of the specified range may occur when properly functioning equipment is affected by the following conditions. Gasoline dispensed into a vehicle fuel tank which is significantly warmer than the dispensed fuel may cause a vacuum of several inches. Conversely, gasoline dispensed into a vehicle tank which is significantly cooler than the dispensed fuel may temporarily cause pressure as high as 1/2 inch water column. The effects of temperature differential will be most pronounced at the beginning of the fueling operation and tend to gradually disappear toward the end of the fueling operation.)

Model 100 Jet Pump

1. A single Model 100 jet pump may not be connected to more than one vapor/liquid hose where more than one hose can be dispensing gasoline simultaneously.
2. Gasoline that flows through the jet pump and components of the jet pump must first be strained by the dispenser filter or by a filter approved by the manufacturer.
3. The Model 100 jet pumps will be set to -70" to -80" water column at the factory with zero vapor flow, and will drop to -15" to -30" when the gasoline nozzle vapor valve opens and vapor flow begins.

Coaxial Hose

1. The length of the coaxial hose shall not exceed 13 feet.
2. A swivel is required on the nozzle end of the coaxial hose. A swivel on the dispenser end of the coaxial hose is optional.

Model 143 Control Valve

1. The Healy Model 143 control valve is required on systems installed which utilize a turbine pump. Systems which utilize a suction pump do not require the Model 143 control valve.

Vapor Line

1. The vapor line connecting the Model 100 jet pump with the coaxial hose adapter shall consist of durable material listed for use with gasoline. It shall be no less than 3/8 inch inside diameter and shall be installed unobstructed.
2. The vapor tube at the top of each side of a multi-product dispenser must be manifolded such that liquid that is taken from either vapor hose cannot enter the vapor path of another hose. The vapor tube extending from the top to the bottom of a dispenser must be 5/8 inch or greater inside diameter.
3. The vapor tube from the bottom of the 5/8 inch or greater line to the jet pump shall be 3/8 inch inside diameter.
4. All vapor return lines must be sloped 1/8 inch per foot minimum. All vapor return lines must be sized to freely drain up to 2 gallons per minute from each jet pump. The vapor return lines are designed to carry liquid product and secondary containment may be required.
5. The riser must be 16 inches or longer and have an inside diameter of no less than 3/4 inch. One-inch inside diameter riser is required with multi-product dispensers. Locate the 1-inch riser with double swing connection to the 2-inch run for best mounting position inside a multi-product dispenser. Allow for 1/2-inch outside diameter copper gasoline tie-in to the regular or lowest octane riser. When a swing joint is used in a riser containing a shear connection, the riser must be rigidly supported.
6. All vapor return and vent piping shall be provided with swing joints at each tank connection, and at the base of the vent riser where it fastens to a building or other structure.

Tank Vents

1. Vent pipes shall be adequately supported throughout their length and when they are supporting weights in addition to their own, additional supports may be required; anchor to building or other structure.
2. Tank vent pipes shall terminate into the open atmosphere and the vent outlet shall be not less than 12 feet above the adjacent ground level.




A pressure/vacuum valve is optional. If a P/V valve is used, it must be Board certified to have a pressure setting of 1 to 3 inches water column and a vacuum setting of -1/2 ounce to -8 inches water column. The vent outlet or P/V valve shall vent upward and be located to eliminate the possibility of vapors accumulating or traveling to a source of ignition or entering adjacent buildings.

3. A Board or district approved leak test is recommended for all new or modified installations. (The leak test contained in Exhibit 5 of this Order is not applicable to Model 100 jet pump systems.) The local district may impose more stringent requirements.

Figure 3-A


Healy Vapor Recovery System with Model 100 Jet Pumps  
Typical Vapor Return Piping Configuration  
With Standard Dispensers



**REVISIONS**

---

SEE EXHIBIT 9, PG. 6-6 AND 6-7



ATTENTION: THE GENERAL NOTES - SHEET 2 OF SHEET NO. 9000-928 ATTACHED.

CARB CERTIFIED PHASE  
VAPOR RECOVERY SYSTEM

**MIRIAM BALSHOR**

JANUARY 7

\$

0.18      600.0      0.00%

FRACTIONS      DECIMALS      ANGLES

INSTRUCTIONS ON SLIDES

USE THESE CHANGES INCREASED

BEAR ALL SHARP CORNERS

DATE: 10/10/2010

ORIGINAL ISSUE DATE	
OWN / <i>JEH</i>	DATE / <i>1152</i>
CHIB	DATE
APPO	DATE
SUBMITTED	
CLIENT	C. I. INC.

# HEAVY

HEALY SYSTEM  
PIPING  
FOR 700 JET PUMP  
ON STAND DISENSED

17 Hampshire Or  
thudson, New Ha


78% 12

1001101

1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100
---	---	---	---	---	---	---	---	---	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	-----

REVISIONS		
REV	DESCRIPTION	DATE
1	ORIG. / SQUE	4-13-98

## Healy Vapor Recovery System with Model 100 Jet Pumps Typical Vapor Return Piping Configuration With Multi-Product Dispensers




**Drawings and Views from the**

# Executive Order G-70-70-AC

## Figure 3-D

### Healy Vapor Recovery System with Model 100 Jet Pumps Typical Installation of Dispenser Components With Standard Dispensers



SEE NOTE-5

9 14

SEE NOTE-2

5 17

17 8

1 4 3

16 13

7 11

6 8

17 16

17 12

2 15

12 15

15 15

15 15

15 15

15 15

15 15

15 15

15 15

15 15

15 15

15 15

15 15

15 15

15 15

15 15

15 15

15 15

15 15

15 15

15 15

15 15

15 15

15 15

15 15

NOTES:

1-DELL 2 TAP 1/4 NPT AT LOCATION SHOWN  
BETWEEN FILTER & PRODUCT METER,  
CLEAN OUT ALL METAL CHIPS BEFORE  
OPERATION.

2-DO NOT BACK OFF ON PIPE THREADS  
TO ALIGN NIPPLE (17) WITH 3/4" HOLE.

3-MAKE 3/4" DIA. HOLE TO PASS THRU 1/2"  
NIPPLE. ATTACH WASHER (ITEM 13)

BEFORE MAKING UP NIPPLE TO HOSE ADAPTER.

4-CONNECT SOLENOID VALVE AT SPARE  
J-BOX FUEL WIRE TO OPERATE IN  
PARALLEL WITH EXISTING MAIN FLOW  
CONTROL VALVE

5-REMOVE 1" NIPPLE WITH PIPE CUTTER. LEAVE  
1 1/2" TO 2" RADIUS HILL AS SHOWN SECTION  
LOCATE 1 3/4" TO GROUND LINE.

DO NOT SCALE THIS DRAWING

REAR ALL SHARP CORNERS

UNLESS OTHERWISE SPECIFIED

TOLERANCES ON

FRACTIONS DECIMALS ANGLES

0.00 0.01 0.1

0.00 0.01 0.1

0.00 0.01 0.1

0.00 0.01 0.1

0.00 0.01 0.1

0.00 0.01 0.1

0.00 0.01 0.1

0.00 0.01 0.1

ORIGINAL ISSUE

DATE

BYN JPM/B

DATE

CHK

DATE

APPROVED

DATE

DATE

DATE

DATE

HEALY SYSTEM  
INSTALLATION

CAMBRIDGE ENGINEERING, INC.


C

197



# Executive Order G-70-70-AC

Figure 3-E

Healy Vapor Recovery System with Model 100 Jet Pumps  
Typical Installation of Dispenser Components  
With Multi-Product Dispensers



NOTE:  
IT-SEE INSTALLATION INSTRUCTION SHEET # 1022 D  
FOR STEP BY STEP PROCEDURE TO FIELD  
RETRO-FIT TYPICAL 6 HOSE MULTI-PRODUCT  
DISPENSER WITH HEALY SYSTEM USING JET-PUMPS  
IT-DO NOT KINK COPPER TUBE WHEN BENDING  
IT-1/2" PIPE BY INSTALLER (2 PCS. APPROX. 7 FT LONG)



## PARTS LIST


ITEM	QTY	DESCRIPTION	PN
1	6	NOZZLE	200
2	6	CO-AXIAL HOSE (13 FT MAX)	75B
3	6	HOSE ADAPTER	016G
4	24	1/4-20 X 3/4 HEX RD BOLT	011
5	24	1/4 FLAT WASHER	012
6	20	ELBOW CONN. (1/4" NPT)	
7	4	1/4"TEE (GALV)	
8	6	1/4" ELBOW (GALV)	
9	12 FT	1/2" OD COPPER TUBE	
10	10	1/2" OD COPPER NIPPLE	
11	4	1/4 X 1/2 REDUCING ELBOW (GALV)	
12	12	1/2" SCH. 40 STD PIPE (GALV)	
13	1		
14	14		
15	15		
16	2	1/4 X 3 NIPPLE	
17	2		
18	2	JET PUMP	100
19	2	RELAY	100G
20	2	CONTROL VALVE	143
21	2		
22	2	SOLANOID VALVE	175
23	2	1/2 X 2 NIPPLE (GALV)	
24	2	FLARE CONN. (1/2" NPT)	
25	0	FLARE CONN. (1/2" NPT)	
26	8 FT.	1/2" OD COPPER TUBE	
27	27		
28	28		

DO NOT SCALE THIS DRAWING


CAMBRIDGE ENGINEERING, INC.	
HEALY SYSTEM INSTALLATION	
SCALE: 1/4" = 1'-0"	DATE: 7/10/1982
COST: \$10.00	SHEET 1 OF 2

ORIGINAL ISSUE	
DATE: 5/10/82	DATE: 5/10/82
BY: JWB	BY: JWB
CHKD: JWB	CHKD: JWB
DATE: 5/10/82	DATE: 5/10/82
SUBMITTED	
CLIENT: C.E. INC.	
MATERIALS	
HEAT TREATMENT	
FINAL PROTECTIVE MEAS.	

# JET PUMP CONTROL MULTI-GRADE DISPENSER (2) REQ. PER DISPENSER



# SUBMERGED TURBINE PUMP CONTROL MULTI-GRADE DISPENSER



Executive Order G-70-70-AC

Figure 3-F


Healy Vapor Recovery System with Model 100 Jet Pumps  
 Wiring Instructions for Multi-Product Dispensers and Submerged Pump Control

DETAILS ALL SHARP CORNERS		ORIGINAL ISSUE		DO NOT SCALE THIS DRAWING	
INSTRUCTIONS	REVISIONS	DATE	BY	DATE	BY
1	1	11/14	11/14	11/14	11/14
TOLERANCES ON DIMENSIONS		CUT DATE		CUT DATE	
FRACTIONS DECIMALS ANGLES		CUT DATE		CUT DATE	
1/16 0.0625 0.1		CUT DATE		CUT DATE	
1/32 0.03125 0.05		CUT DATE		CUT DATE	
1/64 0.015625 0.025		CUT DATE		CUT DATE	
1/128 0.0078125 0.0125		CUT DATE		CUT DATE	
1/256 0.00390625 0.00625		CUT DATE		CUT DATE	
1/512 0.001953125 0.003125		CUT DATE		CUT DATE	
1/1024 0.0009765625 0.0015625		CUT DATE		CUT DATE	
1/2048 0.00048828125 0.00078125		CUT DATE		CUT DATE	
1/4096 0.000244140625 0.000390625		CUT DATE		CUT DATE	
1/8192 0.0001220703125 0.0001953125		CUT DATE		CUT DATE	
1/16384 0.00006103515625 0.00009765625		CUT DATE		CUT DATE	
1/32768 0.000030517578125 0.000048828125		CUT DATE		CUT DATE	
1/65536 0.0000152587890625 0.0000244140625		CUT DATE		CUT DATE	
1/131072 0.00000762939453125 0.00001220703125		CUT DATE		CUT DATE	
1/262144 0.000003814697265625 0.000006103515625		CUT DATE		CUT DATE	
1/524288 0.0000019073486328125 0.0000030517578125		CUT DATE		CUT DATE	
1/1048576 0.00000095367431640625 0.00000152587890625		CUT DATE		CUT DATE	
1/2097152 0.000000476837158203125 0.000000762939453125		CUT DATE		CUT DATE	
1/4194304 0.0000002384185791015625 0.0000003814697265625		CUT DATE		CUT DATE	
1/8388608 0.00000011920928955078125 0.00000019073486328125		CUT DATE		CUT DATE	
1/16777216 0.000000059604644775390625 0.000000095367431640625		CUT DATE		CUT DATE	
1/33554432 0.0000000298023223876953125 0.0000000476837158203125		CUT DATE		CUT DATE	
1/67108864 0.00000001490116119384765625 0.00000002384185791015625		CUT DATE		CUT DATE	
1/134217728 0.000000007450580596923828125 0.000000011920928955078125		CUT DATE		CUT DATE	
1/268435456 0.0000000037252902984619140625 0.0000000059604644775390625		CUT DATE		CUT DATE	
1/536870912 0.00000000186264514923095703125 0.00000000298023223876953125		CUT DATE		CUT DATE	
1/1073741824 0.000000000931322574615478515625 0.000000001490116119384765625		CUT DATE		CUT DATE	
1/2147483648 0.0000000004656612873077392578125 0.0000000007450580596923828125		CUT DATE		CUT DATE	
1/4294967296 0.00000000023283064365386962890625 0.00000000037252902984619140625		CUT DATE		CUT DATE	
1/8589934592 0.000000000116415321826934814453125 0.000000000186264514923095703125		CUT DATE		CUT DATE	
1/17179869184 0.0000000000582076609134674072265625 0.0000000000931322574615478515625		CUT DATE		CUT DATE	
1/34359738368 0.00000000002910383045673370361328125 0.00000000004656612873077392578125		CUT DATE		CUT DATE	
1/68719476736 0.000000000014551915228366851806640625 0.000000000023283064365386962890625		CUT DATE		CUT DATE	
1/137438953472 0.0000000000072759576141834259033203125 0.0000000000116415321826934814453125		CUT DATE		CUT DATE	
1/274877906944 0.00000000000363797880709171295166015625 0.00000000000582076609134674072265625		CUT DATE		CUT DATE	
1/549755813888 0.000000000001818989403545856475830078125 0.000000000002910383045673370361328125		CUT DATE		CUT DATE	
1/1099511627776 0.0000000000009094947017729282379150390625 0.00000000000145519152283668518066015625		CUT DATE		CUT DATE	
1/2199023255552 0.00000000000045474735088646411895751953125 0.00000000000072759576141834259033203125		CUT DATE		CUT DATE	
1/4398046511104 0.000000000000227373675443232059478759765625 0.000000000000363797880709171295166015625		CUT DATE		CUT DATE	
1/8796093022208 0.0000000000001136868377216160297393798828125 0.0000000000001818989403545856475830078125		CUT DATE		CUT DATE	
1/17592186044416 0.000000000000056843418860808014869689944140625 0.00000000000009094947017729282379150390625		CUT DATE		CUT DATE	
1/35184372088832 0.0000000000000284217094304040074348449720703125 0.000000000000045474735088608014869689944140625		CUT DATE		CUT DATE	
1/70368744177664 0.00000000000001421085471520200371742248603515625 0.0000000000000227373675443232059478798828125		CUT DATE		CUT DATE	
1/140737488355328 0.000000000000007105427357601001858711243017578125 0.00000000000001136868377216160297393798828125		CUT DATE		CUT DATE	
1/281474976710656 0.0000000000000035527136788005009293556215087890625 0.00000000000000568434188608014869689944140625		CUT DATE		CUT DATE	
1/562949953421312 0.000000000000001776356839400250464677810754403125 0.00000000000000284217094304040074393798828125		CUT DATE		CUT DATE	
1/1125899906842624 0.000000000000000888178419700125232338905377015625 0.000000000000001421085471520200371742248603515625		CUT DATE		CUT DATE	
1/2251799813685248 0.0000000000000004440892098500626161694526885078125 0.0000000000000007105427357601001858711243017578125		CUT DATE		CUT DATE	
1/4503599627370496 0.00000000000000022204460492503130808472634425390625 0.00000000000000035527136788005009293556215087890625		CUT DATE		CUT DATE	
1/9007199254740992 0.000000000000000111022302462515654042363172126953125 0.0000000000000001776356839400250464677810754403125		CUT DATE		CUT DATE	
1/18014398509481984 0.0000000000000000555111512312578270211815860634765625 0.0000000000000000888178419700125232338905377015625		CUT DATE		CUT DATE	
1/36028797018963968 0.0000000000000000277555756156289135105907930317328125 0.00000000000000004440892098500626161694526885078125		CUT DATE		CUT DATE	
1/72057594037927936 0.0000000000000000138777878078144567552953965186640625 0.000000000000000022204460492503130808472634425390625		CUT DATE		CUT DATE	
1/144115188075855872 0.00000000000000000693889390390722837764769825933203125 0.0000000000000000111022302462515654042363172126953125		CUT DATE		CUT DATE	
1/288230376151711744 0.0000000000000000034694469519536141888238491296640625 0.00000000000000000555111512312578270211815860634765625		CUT DATE		CUT DATE	
1/576460752303423488 0.00000000000000000173472347597680709441192456483203125 0.00000000000000000277555756156289135105907930317328125		CUT DATE		CUT DATE	
1/1152921504606846976 0.000000000000000000867361737988403547205962282416015625 0.00000000000000000138777878078144567552953965186640625		CUT DATE		CUT DATE	
1/2305843009213693952 0.00000000000000000043368086899420177360298114120078125 0.000000000000000000693889390390722837764769825933203125		CUT DATE		CUT DATE	
1/4611686018427387904 0.000000000000000000216840434497100886801490570600390625 0.00000000000000000034694469519536141888238491296640625		CUT DATE		CUT DATE	
1/9223372036854775808 0.0000000000000000001084202172485504434007452853001953125 0.000000000000000000173472347597680709441192456483203125		CUT DATE		CUT DATE	
1/18446744073709551616 0.00000000000000000005421010862427522170037264265009765625 0.00000000000000000008673617379884035472059622824120078125		CUT DATE		CUT DATE	
1/36893488147419103232 0.000000000000000000027105054312137610850186321325048828125 0.000000000000000000043368086899420177360298114120078125		CUT DATE		CUT DATE	
1/73786976294838206464 0.00000000000000000001355252715606880542509316066250244140625 0.0000000000000000000216840434497100886801490570600390625		CUT DATE		CUT DATE	
1/147573952589676412928 0.00000000000000000000677626357803440271254658033125122203125 0.00000000000000000001084202172485504434007452853001953125		CUT DATE		CUT DATE	
1/295147905179352825856 0.0000000000000000000033881317890172013562732901656256111015625 0.0000000000000000000054210108624275221700372642650048828125		CUT DATE		CUT DATE	
1/5902958103587056517056 0.0000000000000000000016940658945086006781366450828128055578125 0.00000000000000000000271050543121376108501863213250244140625		CUT DATE		CUT DATE	
1/11805916207174113034112 0.00000000000000000000084703294725430033906832254140640277890625 0.00000000000000000000135525271560688054250931606625122203125		CUT DATE		CUT DATE	
1/23611832414348226068224 0.000000000000000000000423516473627150169534161270703201389453125 0.0000000000000000000006776263578034402712546580331256111015625		CUT DATE		CUT DATE	
1/47223664828696452136448 0.0000000000000000000002117582368135750847670806353516006947265625 0.00000000000000000000033881317890172013562732901656256111015625		CUT DATE		CUT DATE	
1/94447329657392904272896 0.00000000000000000000010587911840678754238354031767580034736328125 0.00000000000000000000016940658945086006781366450828128055578125		CUT DATE		CUT DATE	
1/188894659314785808545792 0.000000000000000000000052939559203393771191770158837900173681640625 0.000000000000000000000084703294725430033906832254140640277890625		CUT DATE		CUT DATE	
1/377789318629571617091584 0.0000000000000000000000264697796016968855958850794189500868408203125 0.0000000000000000000000423516473627150169534161270703201389453125		CUT DATE		CUT DATE	
1/755578637259143234183168 0.0000000000000000000000132348898008484427979425397094750043421015625 0.00000000000000000000002117582368135750847670806353516006947265625		CUT DATE		CUT DATE	
1/1511157274518286468366336 0.00000000000000000000000661744490042422139897126985473750217105078125 0.000000000000000000000010587911840678754238354031767580034736328125		CUT DATE		CUT DATE	
1/3022314549036572936732672 0.000000000000000000000003308722450212110699485634927368751085525390625 0.0000000000000000000000052939559203393771191770158837900173681640625		CUT DATE		CUT DATE	
1/6044629098073145873465344 0.000000000000000000000001654361225106055349742817463684375542761953125 0.0000000000000000000000026469779601696885595885079418950043421015625		CUT DATE		CUT DATE	
1/12089258196146291746930688 0.0000000000000000000000008271806125530276748714087318421877713809765625 0.000000000000000000000001323488980042422139897126985473750217105078125		CUT DATE		CUT DATE	
1/24178516392292583493861376 0.00000000000000000000000041359030627651383743570436592109388569048828125 0.000000000000000000000000661744490042422139897126985473750217105078125		CUT DATE		CUT DATE	
1/48357032784585166987722752 0.000000000000000000000000206795153138256918717852182960546942845244140625 0.0000000000000000000000003308722450212110699485634927368751085525390625		CUT DATE		CUT DATE	
1/96714065569170333975445504 0.00000000000000000000000010339757656912845935892609148027347142262203125 0.0000000000000000000000001654361225106055349742817463684375542761953125		CUT DATE		CUT DATE	
1/193428131138340667950891008 0.0000000000000000000000000516987882845642296794630457240137357111311015625 0.0000000000000000000000000827180612553027674871408731842187713809765625					

# Executive Order 6-70-70-AC

Figure 3-6

Healy Vapor Recovery System with Model 100 Jet Pumps  
Typical Installation of Dispenser Components  
With Suction Pump Dispensers



## PARTS LIST

ITEM	QTY	DESCRIPTION	P/N
1	1	NOZZLE (.01 LEAD, .02 UNLEAD)	400
2	1	CORAL HOSE (13 FT MAX)	757
3	1	HOSE ADAPTER	04-11
4	1	JET PUMP	100
5	1	HOSE CLAMP	5103
6	1	WASHER, HOLE MASK	109
7	1	BREAKAWAY (OPTIONAL)	8701
8	1	1/4" NIPPLE (GALV)	
9	1	1/4" ELBOW (GALV)	
10	1	3/4" CLOSE NIPPLE	
11	1	3/4" 1" BUSHING (GALV)	
12	4	1/4" METAL 1/2" O.D. COPPER	
13	5 FT	1/2" O.D. COPPER TUBE	

## NOTES:

- 1- MAKE 3/4" DIA. HOSE TO PASS THROUGH 1/4" NIPPLE
- 2- SLIP WASHER (ITEM 6) OVER NIPPLE BEFORE MAKING UP NIPPLE TO HOSE ADAPTER (ITEM 3)
- 3- MAKE GASOLINE CONNECTION AT STAIR 1/4" O.D. LARGEST PIPE JOINT BETWEEN PUMP DISCHARGE & METER INLET. IF UNAVAILABLE 7/8" DRILL & 1/4"-18 NPT TAP AT SUITABLE HEAVY WALL SECTION OF PIPEWAY. REMOVE SECTION FOR DRILL TAP OPERATION TO EXCLUDE METAL CHIPS FROM ENTERING METER.
- 4- DO NOT KINK 1/2" O.D. COPPER TUBE.

— REFERENCE CODES —  
THIS EQUIPMENT TO BE INSTALLED IN ACCORDANCE WITH NFPA-70 AND AUTOMOTIVE & MARINE SERVICE CODE NFPA-30A.

DO NOT SCALE THE DRAWING

ORIGINAL ISSUE	
DATE	DATE
BY	DATE
CHKD	DATE
APPR	DATE
SUBMITTED	DATE
CERT	C.E. INC.
SCALE	
NO. 803	
C 7810-198	

CAMBRIDGE ENGINEERING, INC.	
HEALY SYSTEM INSTALLATION SUCTION PUMP WITH #100 JET PUMP	
DATE	DATE
BY	DATE
CHKD	DATE
APPR	DATE
SUBMITTED	DATE
CERT	C.E. INC.
SCALE	
NO. 803	
C 7810-198	



Executive Order G-70-70-AC

Exhibit 4

Specifications for Healy System with Central Vacuum Unit  
((Model 8500 Multi-Jet or 9000 Mini-Jet))

Drawings of typical installations of Healy vapor recovery systems with a central vacuum unit are shown in Figures 4-A, 4-B, 4-C, 4-D, 4-E, 4-F and 4-G.

Nozzles

1. Systems with a central vacuum unit for which the normal operating range of the vacuum level is -30" to -40" water column may be used only with Model 200 nozzles. Systems with a central vacuum unit for which the normal operating range of the vacuum level is -60" to -80" water column may be used with Model 400 or Model 200(X) nozzles. 200(X) designates Model 200 nozzles which have been modified, by the manufacturer or designated representative only, to operate properly at the higher vacuum level setting. These nozzles have an "X" stamped on the nozzle body following the serial number.
2. Leaded and unleaded nozzle spouts are interchangeable.
3. The nozzle must shut off at a vacuum of -10 inches water column or less and at a pressure of +10 inches water column or greater.
4. Flow rate is limited to 10 gallons or less per minute.
5. The normal operating range in the nozzle boot is -1/4 inch water column to zero (atmospheric pressure). Readings taken during a fueling of at least ten gallons, excluding the first gallon and the last gallon dispensed, should be relatively stable. Fluctuations (except during the first or last gallon) indicate a defective nozzle. A vacuum of -1/2 inch or more, or a pressure of 1/4 inch or more, indicate a defective nozzle or system. (Note: vacuum or pressure levels outside of the specified range may occur when properly functioning equipment is affected by the following conditions. Gasoline dispensed into a vehicle fuel tank which is significantly warmer than the dispensed fuel may cause a vacuum of several inches. Conversely, gasoline dispensed into a vehicle tank which is significantly cooler than the dispensed fuel may temporarily cause pressure as high as 1/2 inch water column. The effects of temperature differential will be most pronounced at the beginning of the fueling operation and tend to gradually disappear toward the end of the fueling operation.)

Central Vacuum Unit

1. Gasoline that flows to the Multi-Jet must be first strained by a filter approved by the manufacturer. The Mini-Jet is direct-coupled to the submerged turbine pump and it has a factory-installed strainer.

2. Any installation with a central vacuum unit which was installed after July 1, 1992, must incorporate a vapor flow control mechanism designed to allow the vapor return line from the dispenser to the central vacuum unit to open only when product dispensing is initiated. The approved vapor flow control mechanisms are listed in Exhibit 1 of this Order. Either the CX6 vapor adaptor or the flow control valve may be used to meet the requirement of this section; the use of both together is neither required nor prohibited. The CX6 vapor adaptor shall be installed as shown in Figure 4-A. The flow control valve shall be installed as shown in Figures 4-F and 4-G.

#### Coaxial Hose

1. The length of the coaxial hose shall not exceed 13 feet.
2. A swivel is required on the nozzle end of the coaxial hose. A swivel on the dispenser end of the coaxial hose is optional.

#### Model 143 Control Valve

1. The Healy Model 143 control valve is included with the Model 9000-02 Mini-Jet to prevent siphon loss when the pump is turned off. The Model 8500 Multi-Jet and the Model 9000-001 Mini-Jet do not have built-in siphons. These units may be installed only when the submerged turbine has a siphon available for gasoline condensate removal.

#### Vapor Line

1. All vapor return lines must be sloped 1/8 inch per foot minimum.
2. The riser must be 16 inches or longer and have an inside diameter of no less than 3/4 inch. One-inch inside diameter riser is required with multi-product dispensers. Locate the 1-inch riser with double swing connection to the 2-inch run for best mounting position inside a multi-product dispenser. Allow for 1/2-inch outside diameter copper gasoline tie-in to the regular or lowest octane riser. When a swing joint is used in a riser containing a shear connection, the riser must be rigidly supported.
3. All vapor return and vent piping shall be provided with swing joints at each tank connection, and at the base of the vent riser where it fastens to a building or other structure.

#### Tank Vents


1. Vent pipes shall be adequately supported throughout their length and when they are supporting weights in addition to their own, additional supports may be required; anchor to building or other structure.
2. Tank vent pipes shall be manifolded at a height not less than 12 feet above the driveway surface used for Phase I tank truck filling operations. A single vertical outlet pipe above the manifold shall be equipped with a pressure/vacuum (P/V) valve. The P/V valve shall be Board certified at a pressure setting of 2 to 3 inches water column and

a vacuum setting of  $-1/2$  ounce ( $-0.8''$ ) to  $-8$  inches water column. For systems installed before July 1, 1992, and for which the normal operating range of the vacuum level is  $-15''$  to  $-40''$  water column, a Board certified P/V valve with a pressure setting of 1 inch may be used. The outlet shall vent upward and be located to eliminate the possibility of vapors accumulating or traveling to a source of ignition or entering adjacent buildings.

3. A Board-approved or district-approved leak test is recommended for all new or modified installations. In addition to any tests which may be required by the local district, the following requirements are made a condition of certification for any installation with a central vacuum unit which was installed or modified to increase the vacuum level setting after July 1, 1992, or for any installation with a central vacuum unit for which the normal operating level is  $-40''$  water column or greater. The owner or operator of the installation shall conduct the leak test in Exhibit 5 of this Order at least once in each twelve month period. Test results which demonstrate that the installation is leak free as specified in Exhibit 5 shall be submitted to the local district. The local district may impose more stringent test frequency requirements or test procedures.

REVISIONS	
BY	DESCRIPTION
A	ORIG. ISSUE

### Healy Vapor Recovery System with Central Vacuum Unit Typical Vapor Return Piping Configuration With Standard or Multi-Product Dispensers



ON 08 NOV 1973 THE

HEALY SYSTEM  
PIPING

**HEALY**  
SYSTEMS, INC.  
7 Hampshire Drive  
Bedford, New Hampshire 03053

1003	826-(006
------	----------

REVISIONS		
REV	DESCRIPTION	DATE
1	ORIG. /SSUE	9/3/92
2		
3		
4		
5		
6		
7		
8		
9		
10		
11		
12		
13		
14		
15		
16		
17		
18		
19		
20		
21		
22		
23		
24		
25		
26		
27		
28		
29		
30		
31		
32		
33		
34		
35		
36		
37		
38		
39		
40		
41		
42		
43		
44		
45		
46		
47		
48		
49		
50		
51		
52		
53		
54		
55		
56		
57		
58		
59		
60		
61		
62		
63		
64		
65		
66		
67		
68		
69		
70		
71		
72		
73		
74		
75		
76		
77		
78		
79		
80		
81		
82		
83		
84		
85		
86		
87		
88		
89		
90		
91		
92		
93		
94		
95		
96		
97		
98		
99		
100		

Executive Order G-70-70-AC

Figure 4-B

Healy Vapor Recovery System with Central Vacuum Unit  
Notes to Accompany Figure 4-A

GENERAL NOTES

1. TEST ALL VAPOR PIPING FROM DISPENSER TO TANK PER HEALY VAPOR RETURN TIGHTNESS TEST PROCEDURE AND DWG. 9801-111 ATTACHED.
2. THIS DRAWING IS FOR ILLUSTRATIVE PURPOSES ONLY. THIS PLAN SHOWS A GENERAL ARRANGEMENT AND IS INTENDED AS A GUIDELINE FOR TYPICAL SINGLE, DUAL, OR MULTIPRODUCT DISPENSERS USING CENTRAL VACUUM VAPOR RECOVERY EQUIPMENT. THE GENERAL ARRANGEMENT SHALL BE MODIFIED TO SUIT INDIVIDUAL INSTALLATION AND CONDITIONS AND IS NOT TO BE USED FOR ACTUAL DESIGN AND INSTALLATION.
3. INSTALLATION SHALL BE IN COMPLIANCE WITH THE REQUIREMENTS SPECIFIED HEREIN, CALIFORNIA AIR RESOURCES BOARD REGULATIONS, CALIFORNIA STATE FIRE MARSHAL REGULATIONS, SUB-CHAPTER 11.5 AND LOCAL APCD RULES.
4. ALL PIPING AND FITTINGS SHALL BE INSTALLED IN ACCORDANCE WITH MANUFACTURER'S INSTRUCTIONS AND SPECIFICATIONS. METAL PIPE SHALL BE MINIMUM SCHEDULE 40 WELDED OR SEAMLESS STEEL PIPE PER ASTM A-53, GALVANIZED, AND FITTINGS SHALL BE 1500 SCREWED MALLEABLE IRON, GALVANIZED. ALL NON-METALLIC PIPE AND FITTINGS SHALL BE UL APPROVED.
5. VAPOR RETURN LINES AND VENT LINES TO BE 2" DIAMETER PIPE UNLESS OTHERWISE NOTED. SLOPE MUST BE MINIMUM 1/8" PER FOOT, WITHOUT SAGS OR TRAPS, DRAINING UNIFORMLY TOWARD PRODUCT STORAGE TANK.
6. VENT LINES MUST BE SEPARATED BY PRODUCT.
7. ALL VAPOR PIPING TRENCHING MUST BE COMPACTED TO 98% UNDISTURBED SOIL BEFORE THE PIPES ARE INSTALLED AND BACKFILLED WITH SAND AT LEAST SIX INCHES BELOW AND ABOVE THE PIPING.
8. THE VAPOR RETURN PIPE SHOULD ENTER A SEPARATE UNDERGROUND TANK OPENING FROM THAT CONNECTED TO THE VENT PIPE OR STAGE 1 PIPING.
9. PRESSURE/VACUUM VALVE #802-21 OR EQUAL SHALL BE INSTALLED ON VENT PIPE.
10. VENT PIPES SHALL BE MANIFOLDED AT MINIMUM HEIGHT OF 12 FEET ABOVE DRIVEWAY LEVEL.
11. TANK GAGE SHALL BE INSTALLED 8 FEET ABOVE DRIVEWAY LEVEL.

SEE ALL SHARP CORNERS

DO NOT SCALE THIS DRAWING

SHEET DIMENSIONS (INCHES)		ORIGINAL SIZE	
LENGTH	WIDTH	DATE	DATE
18" x 24"	18" x 24"	09/03/92	09/03/92
TOLERANCES ON DIMENSIONS		TOLERANCES ON DIMENSIONS	
LENGTH	WIDTH	DATE	DATE
± 0.01"	± 0.01"	09/03/92	09/03/92
TOLERANCES ON DIMENSIONS		TOLERANCES ON DIMENSIONS	
LENGTH	WIDTH	DATE	DATE
± 0.01"	± 0.01"	09/03/92	09/03/92
TOLERANCES ON DIMENSIONS		TOLERANCES ON DIMENSIONS	
LENGTH	WIDTH	DATE	DATE
± 0.01"	± 0.01"	09/03/92	09/03/92

HEALY SYSTEM  
PIPING  
GENERAL NOTES


HEALY SYSTEM  
17 HUNTERS  
HUNTER, NEW I.  
#8 0301

9801-111

# Executive Order G J-70-AC

Figure 4-C

Healy Vapor Recovery System with Central Vacuum Unit  
Typical Installation of Dispenser Components  
With Standard Dispenser



NOTES: 1- MAKE 3/4" DIA. HOLE TO PASS THROUGH 1/2" NIPPLE. ATTACH WASHER (ITEM 6) BEFORE MAKING UP NIPPLE TO HOSE ADAPTER. 2- CUT & INSTALL TUBING (ITEM 5) TO AVOID ANY POSSIBILITY OF KINKING.

REVISIONS		
ITEM	DESCRIPTION	DATE
A	ITEM 3 HAS CHANGED TO 1/2" HOSE 11/15/78	JMM

PARTS LIST		
ITEM	QTY	DESCRIPTION
1	1	NIPPLE (NOT SHOWN) 200000
2	1	CO-AXIAL HOSE (13 FT LG. MIN)
3	1	HOSE ADAPTER
4	2	1/2" O.D. COPPER TUBE
5	1	1/2" O.D. COPPER TUBE
6	1	WASHER, HOLE MARK
7	1	1" CLOSE NIPPLE (GALV)
8	1	1/4" x 2 1/2" NIPPLE (GALV)
9	1	1/4" ELBOW (GALV)
10	1	1/4" BUSHING (GALV)
11	1	1" COUPLING (GALV)

PLEASE ALL SHARP CORNERS

UNLESS OTHERWISE SPECIFIED		ORIGINAL ISSUE	
TOLERANCES ON	ANGLES	DATE	DATE
FRACTIONS	DECIMALS	DATE	DATE
1/16" 0.0625"	0.01"	DATE	DATE
MATERIALS		SUBMITTED	
HEAT TREATMENT		C.L. INC.	
FINAL PROTECTIVE FINISH		CLIENT	


DO NOT SCALE THIS DRAWING

HEALY SYSTEM  
INSTALLATION  
TYPICAL DISPENSER  
WITH CENT VAC. UNIT

CAMBRIDGE ENGINEERING, INC.	
SCALE	NO. REV.
C	8502-124
CODE	INSET

### Figure 4-D

### Figure 4-D Healy Vapor Recovery System with Central Vacuum Unit Typical Installation of Dispenser Components With Multi-Product Dispensers





REVISIONS		
ITEM	DESCRIPTION	DATE
1	ORIG. ISSUE	12-22-52
APPROVED		DATE
		12-22-52
DRAWN		DATE
		12-22-52

# Executive Order G-70-70-AC

Figure 4-E

Healy Vapor Recovery System with Central Vacuum Unit  
Typical Installation of Dispenser Components  
With Balance Vapor-Ready Multi-Product Dispensers



ITEM	QTY	DESCRIPTION	P/N
1	5	NOZZLE	400
2	6	HOSE #75B-100-32FZ	—
3	6	BREAKAWAY	6701
4	6	BIG TAIL	707
5	6	HOSE ADAPTER	67412

DO NOT SCALE THIS DRAWING

UNLESS OTHERWISE SPECIFIED		ORIGINAL ISSUE	
FRACTIONS	DECIMALS	DATE	DATE
1/16	0.0625	12-22-52	12-22-52
1/8	0.125	DATE	DATE
1/4	0.25	DATE	DATE
1/2	0.5	DATE	DATE
3/4	0.75	DATE	DATE
1	1.0	DATE	DATE
2	2.0	DATE	DATE
3	3.0	DATE	DATE
4	4.0	DATE	DATE
5	5.0	DATE	DATE
6	6.0	DATE	DATE
7	7.0	DATE	DATE
8	8.0	DATE	DATE
9	9.0	DATE	DATE
10	10.0	DATE	DATE
11	11.0	DATE	DATE
12	12.0	DATE	DATE
13	13.0	DATE	DATE
14	14.0	DATE	DATE
15	15.0	DATE	DATE
16	16.0	DATE	DATE
17	17.0	DATE	DATE
18	18.0	DATE	DATE
19	19.0	DATE	DATE
20	20.0	DATE	DATE
21	21.0	DATE	DATE
22	22.0	DATE	DATE
23	23.0	DATE	DATE
24	24.0	DATE	DATE
25	25.0	DATE	DATE
26	26.0	DATE	DATE
27	27.0	DATE	DATE
28	28.0	DATE	DATE
29	29.0	DATE	DATE
30	30.0	DATE	DATE
31	31.0	DATE	DATE
32	32.0	DATE	DATE
33	33.0	DATE	DATE
34	34.0	DATE	DATE
35	35.0	DATE	DATE
36	36.0	DATE	DATE
37	37.0	DATE	DATE
38	38.0	DATE	DATE
39	39.0	DATE	DATE
40	40.0	DATE	DATE
41	41.0	DATE	DATE
42	42.0	DATE	DATE
43	43.0	DATE	DATE
44	44.0	DATE	DATE
45	45.0	DATE	DATE
46	46.0	DATE	DATE
47	47.0	DATE	DATE
48	48.0	DATE	DATE
49	49.0	DATE	DATE
50	50.0	DATE	DATE
51	51.0	DATE	DATE
52	52.0	DATE	DATE
53	53.0	DATE	DATE
54	54.0	DATE	DATE
55	55.0	DATE	DATE
56	56.0	DATE	DATE
57	57.0	DATE	DATE
58	58.0	DATE	DATE
59	59.0	DATE	DATE
60	60.0	DATE	DATE
61	61.0	DATE	DATE
62	62.0	DATE	DATE
63	63.0	DATE	DATE
64	64.0	DATE	DATE
65	65.0	DATE	DATE
66	66.0	DATE	DATE
67	67.0	DATE	DATE
68	68.0	DATE	DATE
69	69.0	DATE	DATE
70	70.0	DATE	DATE
71	71.0	DATE	DATE
72	72.0	DATE	DATE
73	73.0	DATE	DATE
74	74.0	DATE	DATE
75	75.0	DATE	DATE
76	76.0	DATE	DATE
77	77.0	DATE	DATE
78	78.0	DATE	DATE
79	79.0	DATE	DATE
80	80.0	DATE	DATE
81	81.0	DATE	DATE
82	82.0	DATE	DATE
83	83.0	DATE	DATE
84	84.0	DATE	DATE
85	85.0	DATE	DATE
86	86.0	DATE	DATE
87	87.0	DATE	DATE
88	88.0	DATE	DATE
89	89.0	DATE	DATE
90	90.0	DATE	DATE
91	91.0	DATE	DATE
92	92.0	DATE	DATE
93	93.0	DATE	DATE
94	94.0	DATE	DATE
95	95.0	DATE	DATE
96	96.0	DATE	DATE
97	97.0	DATE	DATE
98	98.0	DATE	DATE
99	99.0	DATE	DATE
100	100.0	DATE	DATE

REFERENCE CODES —  
THIS EQUIPMENT TO BE INSTALLED IN ACCORDANCE  
WITH NFPA-70 AND AUTOMOTIVE & MARINE  
SERVICE CODE NFPA-50A.

DO NOT SCALE THIS DRAWING

BALANCE CONVERSION  
TO HEALY SYSTEM  
MULTI-PRODUCT DISP

SCALE ~ NO. 1108

CODE ~ INCH OF

CAMBRIDGE ENGINEERING, INC.  
SYSTEMS, INC.

HEALY



MADE IN U.S.A.

9201-401



### Figure 4-F.

## Typical Installation of Dispenser Components



PARTS LIST			P/N
ITEM	QTY.	DESCRIPTION	P/N
1	6	NOZZLE	400
2	6	COD-ANAL HOSE (19 FT. MAX)	757B
3	6	HOSE ADAPTER	CY6U.
4	24	1/4-20 x 3/8 HEX HD BOLT	CX11.
5	24	1/4" FLAT WASHER	CX12
6	20	FLARE CONN. (1/2" T x 1/4" MPT)	
7	5	1/4" TEE (GALV)	
8	6	1/4" ELBOW (GALV)	
9	165T	1/2" OD COOPER TUBE	
10	11	1/4" CLOSE NIPPLE	
11	4	1/4" x 1/2" REDUCING ELBOW (GALV)	
12	3/4" NIPPLE	1/2" STD. 40 STD PIPE (GALV)	
13	1	1/4" x 1 REDUCING COUPING (GALV)	
14	2	SOLENOID VALVE	175
15	6	SOLID STATE RELAY	939
16	2	1/4" NIPPLE	

DO NOT SCALE THE DRAWING

HEALY SYSTEM  
CONVERSION  
MULTI-FLOOD-DISP  
CENTRAL VAC. UNIT

CAMBRIDGE ENGINEERING, INC.  
SYSTEMS,  
INC.

HEADLINE  
MARK  
DATE  
JOB NO.  
C &  
1-125G  
SHEET 1 OF 2

SCALE INCHES FEET

ORIGINAL SIZE

DRAWN BY DATE

CHECKED DATE

APPROVED DATE

SUBMITTED

C.E. INC.

CLIENT

UNLESS OTHERWISE SPECIFIED

TOLERANCES ON DIMENSIONS ARE AS SHOWN

FRACTIONS DECIMALS ANGLES

AS SHOWN

IN ALL CASES

DETAILS

TREATMENT

ALL PROTECTIVE FINISH

1-1/2" PIPE TO BE INSTALLED (2' RES.; APPROX. 7 FT. LG.).  
2-REMOVE EXISTING HOSE OUTLETS & WELD FLOT COVERS.  
3-INSTALL C. HOSE ADAPTERS & CONNECT 3/4" NPT GASOLINE.  
4-INSTALL 1/2" OR PIPE FITTINGS & 1/2" O.D. COPPER FITTINGS  
MODIFIED DONUT RUN DIRECTLY OVER & REST IN CYCLU.  
5-OO NOT KN. 1/2" O.D. TUBE WHEN BENDING..

**Figure 4-G**

DIVISIONS	
SYS	DISCUSSION
A	02/16, 1530E



00 104 3121 144 104 00

FOR CONTROL OF  
WEAVING DIAGRAM

175 HEELY WAREHOUSE  
IN MULT-PROD. DISR

0.018 00	0.018 00
----------	----------

03

5	:
0	:

[illegible]

03

5	:
0	:

[illegible]

Executive Order G-70-70-AC

Exhibit 5

Healy System Vapor Return Leak Tightness Test Procedure

- | STEP | PROCEDURE  |
|------|--|
| ①    | Connect 0-100" WC gage at 1/4" plug location for vacuum test (see Dwg. 9001-111 at 1" Tee between 1" ball valve in vapor inlet line and end of 2" underground vapor return).   |
| ②    | Turn on Multi-Jet/Mini-Jet by turning on any dispenser--hang nozzle to maintain Multi-Jet/Mini-Jet vacuum (all nozzles must be closed and must remain closed throughout the test).   |
| ③    | Read 0-100" WC gage.   |
| ④    | Close 1" ball valve in vapor inlet line and the 1/4" ball valve in syphon line and observe 0-100" WC gage with all nozzles closed: <ul style="list-style-type: none"><li>a. Gage holds steady--this means that all vapor piping from the ball valves out to each and every nozzle is tight. Proceed to Step 5.</li><li>b. Gage vacuum levels fall quickly--for example, -70" WC to -50" WC in 30 seconds. Proceed to Step 7.</li></ul>   |
| ⑤    | Place 1/2-mil-thick plastic dry cleaning bag over vent discharge to atmosphere (remove pressure/vacuum valve if installed at this station). Bag to be closed with string-tie gather on one end and elastic band sealed around vent pipe other end. (Typical dry cleaning bag volume is 18 1/2 gallons.)  |
| ⑥    | With bag empty and ball valves closed, turn on Multi-Jet/Mini-Jet and measure time to fill until just tight. <ul style="list-style-type: none"><li>a. If bag remains slack while Multi-Jet/Mini-Jet is running with 1" ball valve on vapor inlet and the 1/4" ball valve on the syphon line closed, there is no vacuum leak from the ball valves to the tank. Test is complete and system is operating correctly.</li><li>b. If bag inflates, this indicates vapor system is leaking air in somewhere between 1" ball valve and discharge of Multi-Jet/Mini-Jet or between 1/4" ball valve and syphon connection. Find leak as follows and repair.</li><li>c. With ball valves closed connect 0-100" WC pressure gage to tank test port and cap all tank vent lines.</li><li>d. Remove 1/4" pipe plug from top of Multi-Jet cover or the 3/4" pipe plug from the top of the Mini-Jet. <b>WARNING: TO AVOID GASOLINE SPLASHBACK DO NOT SHUT OFF MULTI-JET/MINI-JET UNLESS 1/4" or 3/4" PIPE PLUG IS REPLACED.</b></li></ul> |

- e. Turn on the Multi-Jet/Mini-Jet and observe the pressure rise on tank test gage until pressure reaches +10" WC. **WARNING: DO NOT ALLOW MULTI-JET/MINI-JET TO RUN BEYOND THIS PRESSURE AS POSITIVE PRESSURE MAY INCREASE TO +75" WC.**
- f. Replace 1/4" or 3/4" pipe plug then shut off the Multi-Jet/Mini-Jet. The entire tank vapor space and all piping between the tank and the ball valves, including the Multi-Jet/Mini-Jet, will be pressurized to +10" WC.
- g. Using soapy-water spray, find leak and repair. If no bubbles appear the leak would be in the electrical conduit wire seal of the 8500 Multi-Jet. (The 9000 Mini-Jet and the non-solenoid 8500-NS version of the Multi-Jet do not have electrical connections.)

⑦ Disconnect vapor connections to 1" pipe riser under all dispensers and seal openings with rubber tubing, plugs, or other means (see Dwg. 9001-111).

⑧ Open both ball valves and read 0-100" WC gage at test port in 1" vapor inlet pipe to Multi-Jet/Mini-Jet.

⑨ Close both ball valves and observe 0-100" WC gage:

- a. Gage steady--means vapor piping to all dispensers is tight. Proceed to Step 10.
- b. Vacuum level falls--indicating piping leak. Record time required to drop 27" WC (i.e., -70" to -43") and estimate length of 2" vapor piping in entire station. Calculate leak rate:

$$\text{GPM (Leak Rate)*} = \frac{\text{Length (Feet)}}{100 \times \text{Time (Min.)}}$$

\*Multiply answer by 2.25 for 3" vapor pipe size.

c. Repair leak if in excess of 1/4 GPM.

⑩ Reconnect one dispenser vapor piping to its risers. Open 1" ball valve and read 0-100" WC gage.

⑪ Close 1" ball valve and observe 0-100" WC gage:

- a. Gage steady--means no leaks all hoses and plumbing to each nozzle this dispenser. Proceed to Step 12.
- b. Gage falls from -70" WC to -50" WC in 30 seconds--large vapor leak this dispenser. Repair as required.

⑫ Disconnect vapor piping from 1" riser and reseal at 1" riser under dispenser.


⑬ Repeat Steps 11 and 12 for each dispenser.

**NOTE: MAKE SURE BOTH 1" BALL VALVE AND 1/4" BALL VALVE ARE OPEN FOR NORMAL SERVICE STATION OPERATION**

⑭ Reconnect all dispensers to vapor return pipe risers and repeat Step 4 to verify system tightness.

### Figure 5-A

### Healy Vapor Return Leak Tightness Test Schematic



## 8500 Multi-Jet Installation

NEAR ALL THEIR COUNTRY

[illegible]

**GRANTING THE EVIDENCE**

# VAPOR RETURN TIGHTNESS TEST SCHEMATIC

**HEADY** **C** **SYSTEMS, INC.**  
CAMDEN ENGINEERING, INC.

**PROTON, CITY MARKETING**

9001-111

SCALE 1/4"	NO 10078.
------------	-----------

Page 10 of 10